



RFB #2016-18 SPRING CREEK BRIDGE PROJECT ADDENDUM 2

8/22/2016

The following changes are hereby added to and made part of Bid #2016-18:
Questions, Answers, Clarifications and Revisions:

Q. Is A55 steel with no primer acceptable?

A. Yes

Q. Is a pre-fab concrete bridge acceptable?

A. No

Q. Is the Contractor responsible for signage?

A. No, the County will provide signage.

Q. Is the Contractor responsible for brush removal and if so how much brush can we remove?

A. The Contractor is responsible for any brush removal required to install the bridge and is authorized to remove whatever amount is needed for the project.

Q. What is the high water mark and how high must be bridge be above the high water mark?

A. The high water mark appears to be just below (approximately 6 inches) the current bridge elevation. Bid a bridge design that elevates the bridge a minimum of 12 inches above the elevation of the bank with an approach on each side to smooth out the transition.

Reminder - Bid due date and time: 8/31/2016 @ 2:00 PM

Late bids will be rejected. There will be a public opening for this bid in the Purchasing Department, 1462 Strongs Ave, Stevens Point, WI 54481.

*****End of Addendum 1*****

FIRM NAME _____ PHONE# _____

AUTHORIZED SIGNATURE

TITLE

Include this signature page with your submittal